



परामर्श खण्ड/ Consultancy Wing

Dated: 13.07.2012

Ref: CW-EN-9661-H-43/006

Mr. N.K.Manwani, AGM (QAX) BHEL HEEP, Ranipur, HARDWAR – 249 403

Sub: BTG package for SCCL Project (2x600MW):TG portion: BHEL's sub supplier proposal of M/s Techno Instruments, Ahmedabad for supply of Thermocouple (TC), RTD Assembly and Thermowell (Excluding IP Inner casing Thermocouple).

Dear Sir,

This has the reference to subject proposal of M/s BHEL – Hardwar. NTPC team along with M/s BHEL – HWR representative visited vendor works on 20.06.2012. In this regards following may please be noted.

NTPC is agreed to M/s BHEL Hwr's proposal to supply <u>Thermocouple</u> (TC), RTD Assembly <u>and Thermowell</u> (Excluding IP Inner casing Thermocouple) from M/s Techno Instruments having work address "1145/1, Opp. Maruti Industries, Uma Converter Lane, Santej, Ranchhodpura Road, Santej, Tal – Kalol - 382721" subject to following.

- 1. Carrying out N2 leak test for weld closure conformity as per IEC standard on 100 % basis.
- 2. Calibration test for the proposed lot to be carried out with standard calibrated reference thermo couple.

However item to be supplied as per NTPC Specification, DATA SHEET requirements and testing will be done as per agreed QP, treating the NTPC inspection category as CAT – I.

Thanking you.

Yours faithfully,

(Sunil Jumde) (AGM Engg/ NTPC CW) Engineering Coordinator SCCL Project

CC: SCCL Hyderabad: by e mail DGM QA C&I/NTPC Sh S Samanta

